

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:58 am

PWS ID: UTAH09051 **Name:** PANGUITCH LAKE GENERAL STORE
Legal Contact: PANGUITCH LAKE GEN STORE **Rating:** Approved
ED OWENS **Rating Date:** 11/17/2004
Address: 55 WEST HIGHWAY 143 **Activity Status:** Active
PANGUITCH, UT 84759
Phone Number: 435-676-2859
City Served (Area):
County: GARFIELD COUNTY

System Type: Non-community **Last Inv Update:** 12/14/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/18/2010 **Total Dsgn Cap:**
Population: 31 **Surveyor:** JOHN GALLIS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	OWENS, ED		435-676-2859		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Commercial	Unknown	0	15
			15 Total Svc Connections

Storage

Total Storage: 8,250 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST002	BOOSTER-HYDROPNEUMATIC TAN	Hydropneuma	50 GAL			A	YES
ST001	T-001	Ground	8,200 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL NO. 1	Inactive	WL	6	5 GPM	50 GPM	Yes	GW	Other		
WS002	WELL NO. 2	Active	WL	6	12 GPM	12 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.